


NOTES:

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE
 - 36" FOR PIPE UP TO AND INCLUDING 12" DIAMETER
 - O.D. PLUS 18" FOR PIPE LARGER THAN 12" NOMINAL DIAMETER
2. REFER TO CITY OF EDMONDS MODIFICATIONS TO DIVISION 9 OF WSDOT STANDARD SPECIFICATIONS FOR MATERIAL GRADATION AND ADDITIONAL INFORMATION.
3. TRENCH BACKFILL SHALL MEET A MINIMUM COMPACTION OF 95% DENSITY PER ASTM D 1557.
4. IF UNSTABLE MATERIAL IS ENCOUNTERED BELOW PIPE ZONE, CONTRACTOR SHALL REMOVE AND REPLACE AS REQUIRED BY CITY ENGINEER.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

TYPICAL TRENCH SECTION

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
GU-400