



SUBSURFACE OVERFLOW CONTROL STRUCTURE

NOTES:

1. UNDERDRAIN PIPE SHALL BE 6" MINIMUM DIAMETER (PRIVATE), 8" DIAMETER MINIMUM (PUBLIC). SLOPE PIPE AT 0.5% MIN UNLESS OTHERWISE SPECIFIED. PROVIDE ONE CLEANOUT (MIN) PER 100 FEET OF UNDERDRAIN, AND AT EACH END.
2. SEE STD DETAIL SD-621 THROUGH SD-624 FOR PERMEABLE PAVEMENT SECTION.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**PERMEABLE PAVEMENT
UNDERDRAIN WITH
CONTROL STRUCTURE**

APPROVED BY: R. ENGLISH

REVISION DATE
DECEMBER 2017

STANDARD
DETAIL
SD-628