


* BOTH RISER PIPE AND INSERT PIPE CAN BE EXTENDED—CONTACT MANUFACTURER.

NOTES:

1. THREADED PLUG, FEMALE ADAPTER, INSERT PIPE, AND RISER PIPE MAY BE SUPPLIED BY OTHERS.
2. BACKFLOW PREVENTER SHALL BE LOCATED FROM HOUSE BETWEEN 2' TO 4'.
3. BACKFLOW PREVENTER VALVE SHALL BE A CLEAN CHECK, INC. MODEL #: EBV-P401 OR EQUIVALENT.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**SIDE SEWER
BACKFLOW PREVENTER**

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
SS-211