


**NOTES:**

1. REFER TO CITY HANDOUT E61 FOR ADDITIONAL DESIGN AND PERMIT REQUIREMENTS.
2. ASSEMBLIES SHOULD NOT BE PLACED IN AREAS SUBJECT TO VEHICULAR TRAFFIC. IF LOCATED IN TRAFFIC AREAS, THE LID SHALL BE TRAFFIC RATED AND SHALL BE INSTALLED FLUSH IN ASPHALT OR CONCRETE.

**CITY INSPECTION REQUIRED  
PRIOR TO BACKFILL**



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**24" SIMPLEX GRINDER  
PUMP WITH REMOTE  
MOUNTED CONTROL PANEL**

APPROVED BY: **R. ENGLISH**

REVISION DATE  
**JANUARY 2018**

STANDARD  
DETAIL  
**SS-241**