


STANDARD TYPE "A" CURB/GUTTER
(NOT TO SCALE)

NOTES:

1. CITY INSPECTION REQUIRED ON FORM WORK PRIOR TO POUR.
2. FORMS SHALL BE TRUE TO LINE AND GRADE AND SECURELY STAKED.
3. EXPANSION JOINTS SHALL BE PLACED ADJACENT TO ANY STRUCTURE.
4. EXPANSION JOINTS SHALL BE EVERY 10 FEET.
5. EXPANSION JOINTS SHALL HAVE 1/2" TO 5/8" WIDE PREMOLDED JOINT FILLER.
6. CONCRETE SHALL BE CLASS 3000.
7. FINISH SHALL BE LIGHT BROOM.
8. CURB SHALL BE SPRAYED WITH CLEAR CURING COMPOUND OR SHALL BE COVERED AND KEPT MOIST FOR 72 HOURS.
9. REMOVAL/REPLACEMENT OF CONCRETE CURB SHALL BE FROM EXPANSION TO EXPANSION JOINT, UNLESS OTHERWISE DIRECTED BY CITY ENGINEER.
10. A 2-FT MINIMUM ASPHALT SAWCUT MAY BE REQUIRED AS DETERMINED BY CITY ENGINEER.
11. CURB/GUTTER SHALL BE 18" OR AS DIRECTED BY CITY ENGINEER.
12. ALL VERTICAL EDGES SHALL BE TACKED.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**CONCRETE CURB
AND GUTTER**

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
TR-520