


NOTES:

1. J-BOLT DIAMETER:
 - PIPE DIAMETER LESS THAN OR EQUAL TO 6": 7/8", 6" & 8" PIPE: 1", 10" = 1-1/4"
 - PIPE DIAMETER GREATER THAN 12": 1-1/2"
2. TIGHTEN TOP NUTS TO TENSION BOLTS
3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**PIPE CLAMP AND ANCHOR
RODS FOR CONCRETE
BLOCKING**

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2017

STANDARD
DETAIL

WA-154