


NOTES:

SIDE VIEW

FRONT VIEW (METER SIDE)

1. PROVIDE CITY APPROVED SUPPORT FOR DEVICES LARGER THAN 1" DIAMETER.
2. OWNER SHALL FURNISH, INSTALL AND MAINTAIN THE RPBA OR RPDA AND ALL PIPING AND APPURTENANCES SHOWN ON THIS PLAN.
3. MUST BE TESTED AFTER INSTALLATION AND YEARLY BY A WASHINGTON STATE CERTIFIED BACKFLOW ASSEMBLY TESTER. TEST RESULTS MUST BE SENT TO THE CITY OF EDMONDS WATER DIVISION.
4. REDUCED PRESSURE BACKFLOW ASSEMBLIES SHALL BE STATE APPROVED DEVICES.
5. ANNUAL TESTING OF RPBA AND RPDA REQUIRED BY OWNER. TEST RESULTS SHALL BE SENT TO THE CITY OF EDMONDS PUBLIC WORKS.
6. DRAIN SHALL BE SIZED IN ACCORDANCE WITH AWWA CROSS CONNECTION CONTROL FIGURE 6-8 (SEE COE STD DTL WA-160C).
7. ENCLOSURES SHALL BE LOCATED ON PRIVATE PROPERTY.
8. SLEEVE SHALL BE ONE NOMINAL SIZE DIAMETER LARGER THAN PIPE BEING SLEEVED.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**HOT BOX ASSEMBLY FOR
REDUCED PRESSURE BACKFLOW
ASSEMBLY (RPBA AND RPDA)**

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
WA-160B