


NOTES:

1. APPROVED PRESSURE VACUUM BREAKER ASSEMBLY MUST BE INSTALLED VERTICALLY, 12" MIN. – 5' MAX ABOVE THE HIGHEST POINT OF USE AND ALL DOWN STREAM PIPING.
2. DESIGNED FOR BACK SIPHONAGE ONLY, NOT FOR BACK PRESSURE.
3. THOROUGHLY FLUSH LINES PRIOR TO INSTALLATION OF BACKFLOW PREVENTER.
4. IF A PVBA IS INSTALLED INDOORS, CONSIDERATION MUST BE GIVEN TO WATER LEAKAGE IF THE BACKFLOW PREVENTER FAILS (EXCESSIVE WATER SPILLAGE).
5. DO NOT INSTALL IN AN AREA SUBJECT TO FLOODING.
6. MUST BE PROTECTED FROM FREEZING CONDITIONS.
7. THE BACKFLOW ASSEMBLY SHALL BE A STATE APPROVED MODEL.
8. A PLUMBING PERMIT IS REQUIRED – PLEASE OBTAIN PERMIT FROM CITY OF EDMONDS DEVELOPMENT SERVICES DEPARTMENT.
9. MUST BE TESTED AFTER INSTALLATION AND YEARLY THEREAFTER BY WASHINGTON STATE CERTIFIED BACKFLOW ASSEMBLY TESTER. TEST RESULTS SHALL BE SENT TO THE CITY OF EDMONDS WATER DIVISION.

(ABOVE GROUND INSTALLATION ONLY)



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**PRESSURE VACUUM
BREAKER ASSEMBLY (PVBA)
2" AND SMALLER**

APPROVED BY: R. ENGLISH

REVISION DATE
JANUARY 2018

STANDARD
DETAIL
WA-166