


**NOTES:**

1. BACKFILL SHALL BE PER COE STD DTL GU-400.
2. ALL FITTINGS AND PIPE JOINTS MUST BE MECHANICALLY RESTRAINED.



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**FIRE LINE  
AND 2" DOMESTIC  
SERVICE CONNECTIONS**

APPROVED BY: **R. ENGLISH**

REVISION DATE  
**JANUARY 2018**

STANDARD  
DETAIL  
**WA-180**