


NOTES (BLDGS WITHOUT SETBACKS):

1. THE PIV AND FDC SHALL BE LOCATED ON THE EXTERIOR WALL OF THE BUILDING OR IN A LANDSCAPED AREA. AT NO TIME SHALL THE PIV OR FDC BE LOCATED IN THE PUBLIC SIDEWALK.
2. THE DCDA SHALL BE LOCATED ON THE INTERIOR WALL OR IN A ROOM ADJACENT TO THE RIGHT-OF-WAY WHERE THE FIRELINE TIES INTO THE CITY MAIN.
3. THE PIV AND FDC SHALL HAVE A 3' MINIMUM CLEARANCE BETWEEN AND AROUND THEM.
4. THE SENSUS ECR/WP REMOTE READER SHALL BE PLACED ON THE EXTERIOR WALL OF THE BUILDING 4' ABOVE FINISHED GRADE.
5. THE FDC SHALL BE 4" PIPE AND HAVE A 22' BEND WITH 4" STORZ ADAPTER ON THE END.
6. THE WATER METER SHALL BE LOCATED AT THE PROPERTY LINE WHENEVER POSSIBLE. LOCATION OTHER THAN THE PROPERTY LINE, SHALL BE DETERMINED BY THE CITY INSPECTOR.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**FIRE LINE & 2" DOMESTIC
SERVICE CONNECTIONS (PLAN VIEW)**

ZERO-SETBACK
BUSINESS/COMMERCIAL ZONES

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL

WA-183