


IF ROCKERY ABUTS A PRIVATE DRIVE OR DRIVEWAY, A 2' SHY DISTANCE SHALL BE MAINTAINED BETWEEN THE WALL FACE AND EDGE OF ROAD SURFACE

ROCKERIES SHALL NOT BE CONSTRUCTED IN CITY R.O.W. OR OVER PUBLIC EASEMENTS

GENERAL NOTES:

1. SPECIAL INSPECTOR SHALL VERIFY ROCKERY HEIGHT, FOUNDATION MATERIAL, AND ROCK SIZE.
2. QUARRY SPALLS AND CRUSHED ROCK SHALL BE PLACED DIRECTLY FROM TRUCK OR OTHER SUITABLE CONTAINER IN ORDER TO MAINTAIN CLEAN BACKFILL.
3. OPENINGS SHALL BE 'CHINKED' WITH QUARRY SPALLS.
4. ROCKERIES SHALL BE DESIGNED AND STAMPED BY A LICENSED PROFESSIONAL ENGINEER IF GREATER THAN 8 FEET IN HEIGHT OR IF VARYING FROM THESE STANDARDS, OR IF THE CITY DETERMINES THAT SPECIAL CONDITIONS (SUCH AS CRITICAL AREA OR MEADOWDALE EARTH SUBSIDENCE LANDSLIDE HAZARD AREA) EXIST.

ROCK SCHEDULE		
WALL HEIGHT	MINIMUM ROCK SIZE	
	BASE	TOP
2 FEET	2-MAN	2-MAN
4 FEET	3-MAN	2-MAN
6 FEET	4-MAN	2-MAN
8 FEET	5-MAN	2-MAN



CITY OF EDMONDS

REVISIONS		STANDARD DETAIL		
APPROVED BY	DATE	ROCKERY DETAIL		
D. GEBERT	09/09/2005			
DATE	4/1/03	SCALE	NTS	DWG NO.
				E 8.9