


GENERAL NOTES:

1. REFER TO 2022 CITY OF EDMONDS STORMWATER ADDENDUM FOR SETBACK (CHECKLIST 12) AND INFESIBILITY REQUIREMENTS.

NOTES:

1. RAIN GARDEN SHALL BE 5 FEET MINIMUM FROM BUILDINGS WITHOUT BASEMENT AND 10 FEET MINIMUM FROM BUILDINGS WITH BASEMENTS.
2. SHEET FLOW INTO RAIN GARDEN MUST BE KEPT WIDELY DISTRIBUTED OVER A STABILIZED SURFACE (PAVEMENT, PEA GRAVEL, GRASS). IF CONCENTRATED FLOW, PROVIDE A SWALE PER STD DETAIL SD-604.
3. TOTAL HARD SURFACE AREA CONTRIBUTING RUNOFF TO RAIN GARDEN MUST BE LESS THAN 5,000 SQUARE FEET.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**TYPICAL RAIN
GARDEN PLAN**

APPROVED BY: R. ENGLISH

REVISION DATE
SEPTEMBER 2023

STANDARD
DETAIL
SD-601