


**NOTES:**

1. SEWER PIPE SHALL BE SDR-35 AND JOINTS SHALL BE GASKETED.
2. PIPE SLOPE TO BE 2% MIN AND UP TO 50% MAX.
3. SEWER CLEANOUT LID TO BE 12" CAST IRON CLEANOUT COVER WITH 1/2" HEX BOLTS AND A PICK HOLE. EAST JORDAN IRON WORKS PRODUCT #00366102 OR APPROVED EQUAL.
4. LEVELING COLLAR SHALL BE CONSTRUCTED AS FOLLOWS:
  - IN ROADWAYS PER COE STD DWG GU-424
  - IN SIDEWALK/LANDSCAPED AREAS, EITHER 24"x24"x6" DEEP CONCRETE COLLAR OR 24" DIAMETER x 6" DEEP CONCRETE COLLAR
5. TWO-WAY CLEANOUT SHALL ONLY BE USED IN CITY ROW/EASEMENTS. WITH APPROVAL FROM THE CITY ENGINEER, IT SHALL BE USED IN LIEU OF A ONE-WAY CLEANOUT, IF ONE-WAY CLEANOUT CANNOT BE PHYSICALLY INSTALLED AT THE EDGE OF ROW/EASEMENT. TWO-WAY CLEANOUT SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO EDGE OF ROW/EASEMENT.
6. TWO-WAY CLEANOUTS SHALL NOT BE INSTALLED ON PRIVATE PROPERTY.



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**SEWER CLEANOUT DETAILS**

APPROVED BY: R. ENGLISH

REVISION DATE  
MARCH 2024

STANDARD  
DETAIL  
SS-200A