



NOTES:

1. IF NEW MAIN IS BEING INSTALLED OR MAIN IS BEING REPLACED, SERVICE CONNECTION TO THE MAIN SHALL BE DONE WITH A WYE AND A 1/8 BEND. WYE SHALL BE AT A 45 DEGREE ANGLE FROM PIPE SPRINGLINE.
2. IF CONNECTING EXISTING PRIVATE SIDE SEWER TO NEW CITY LATERAL, A CONCRETE/PVC STRONGBACK FERNCO RC SERIES OR ROMAC COUPLING SHALL BE USED AND SECURED PER MFR'S INSTRUCTIONS.
3. BORING OF SERVICES WITHIN RIGHT OF WAY IS NOT ALLOWED.
4. SEWER PIPE SHALL BE SDR-35 AND JOINTS SHALL BE GASKETED.
5. IF STUB FOR FUTURE DEVELOPMENT, USE RUBBER JOINT BISCUIT PLUG OR OTHER APPROVED WATERTIGHT PLUG.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

NEW LATERAL SEWER FOR NEW SEWER MAIN PIPE

APPROVED BY: R. ENGLISH

REVISION DATE
FEBRUARY 2023

STANDARD
DETAIL
SS-203