



NOTES:

1. DROP BOWLS SHALL BE A RELINER-DURAN DROP BOWL KIT OR EQUAL AS APPROVED BY CITY.
2. SIZE OF DROP BOWL & DROP PIPE SHALL BE EQUAL TO INLET PIPE.
3. INSTALL PER MANUFACTURER'S SPECIFICATIONS.
4. INSIDE DROP SYSTEM ALLOWED ONLY WITH PRIOR CITY OF EDMONDS APPROVAL.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

PVC INSIDE DROP SYSTEM MANHOLE

APPROVED BY: R. ENGLISH

REVISION DATE
FEBRUARY 2023

STANDARD
DETAIL
SS-220