


NOTES:

1. CATCH BASINS SHALL BE CONSTRUCTED IN ACCORDANCE WITH WSDOT STANDARD SPECIFICATION 9-05.50(3).
2. HANDHOLDS IN ADJUSTMENT SECTION SHALL HAVE 3" MIN CLEARANCE. STEPS IN CATCH BASIN SHALL HAVE 6" MIN CLEARANCE.
3. APPLY NON-SHRINK GROUT TO INSIDE AND OUTSIDE OF ALL JOINTS, RINGS, PICK HOLES, RISERS AND FRAMES. ALL PRECAST CONCRETE SHALL BE CLASS 4000.
4. STEP AND LADDER SHALL BE ORIENTED TO AVOID INSTALLATION ABOVE PIPE.
5. CATCH BASIN FRAMES AND GRATES OR COVERS SHALL BE IN ACCORDANCE WITH SEC 7.05 OF THE WSDOT STANDARD SPECIFICATIONS.
6. STEP AND LADDER MAY BE USED IN LIEU OF POLYPROPYLENE SAFETY STEPS. SEE COE STD DTL GU-423.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

CATCH BASIN
TYPE II

APPROVED BY: R. ENGLISH

REVISION DATE
SEPTEMBER 2023

STANDARD
DETAIL
SD-300A