


**NOTES:**

1. ALL STEEL PARTS MUST BE GALVANIZED AND ASPHALT COATED (TREATMENT 1 OR BETTER).
2. CONTRACTOR TO VERIFY DIMENSIONS.
3. TO BE USED ON PIPE INLETS OF DETENTION PONDS AND ON INLET OF PIPES GREATER THAN 18" DIAMETER. DO NOT USE IN PIPE OUTFALLS.



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**TRASH RACK/  
DEBRIS BARRIER**

REVISION DATE  
**JANUARY 2018**

STANDARD  
DETAIL  
**SD-330**

APPROVED BY: **R. ENGLISH**